



# Aberdeen Fire Rescue Department

*Serving the community since 1921*

910-944-7888

800 HOLLY STREET  
ABERDEEN, NC 28315

Fax: 910-944-9755



## Sprinkler Systems

Building: \_\_\_\_\_

Address: \_\_\_\_\_

Inspector: \_\_\_\_\_ Date: \_\_\_\_\_

Date of Last Inspection: \_\_\_\_\_ Outstanding Violations: Yes  No

### GENERAL

Date Sprinklers installed: \_\_\_\_\_

Were building alterations/renovations made since last inspection? Yes  No

Was a new sprinkler added since last inspection? Yes  No

Any sprinkler system alteration made since last inspection? Yes  No

What is system type? Wet  Dry  Preaction  Deluge

Is building fully protected with sprinklers? Yes  No

If not, explain:

### Sprinkler Valves

Do sprinkler valves appear in good working order? Yes  No

Is dry pipe valve in heated enclosure? Yes  No

Are spare sprinklers provided? Yes  No

### Control Valves

Are control valves sealed? Yes  No

Are they locked? Yes  No  N/A

Do they have tamper switches? Yes  No  N/A

### Fire Department Connections

Are fire department connections clear and unobstructed? Yes  No  N/A

Are protective caps in place? Yes  No  N/A

Are connections identified? Yes  No  N/A

### Inspections and Tests Recorded

Are quarterly inspections and tests recorded? Yes  No  N/A

Are semiannual inspections and tests recorded? Yes  No  N/A

Are annual inspections and tests recorded? Yes  No  N/A

**Inspections and Tests Recorded**

Are 3 year dry Pipe full flow trip tests recorded? Yes  No  N/A

Are 5 year alarm valve internal inspection recorded? Yes  No  N/A

20 Years – Is sample of fast response sprinklers tested? Yes  No  N/A

50 Years – Is sample of standard response sprinklers tested? Yes  No  N/A

**Notes:**

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

Fire Inspector \_\_\_\_\_

Date: \_\_\_\_\_