

## **2016 Sewer Collections System Performance Report**

Facility/System Name: Town of Aberdeen

Responsibility Entity: Town of Aberdeen Public Works Department

Person in Charge/Contact: James Robert Matthews

Applicable Permit (s): Grade II Collections System Only

Description of Collection System or Treatment Process: Approximately 20 miles of sanitary sewer main; approximately two miles of sanitary forced sewer main; seven sewer lift pump stations – treatment is provided by Moore County.

Text summary of System Performance for Calendar Year 2016

Overall the Town's sewer system is in good shape. The main issues we encounter in our system stem from inflow & infiltration and root and grease buildup in the lines. We are consistently replacing old sewer lines, videotaping to identify trouble areas and sealing older manholes.

2016 We did not have any violations

Spills that were less than the required overflow, we have not listed. Spills that do not enter surface water are dammed up to prevent spreading downstream and treated with an application of lime and then removed and taken to the Moore County Waste Water Treatment Plant.

I certify under penalty of law that this report is complete and accurate to the best of my knowledge. I further certify that this report has been made available to the users or customers of the named system and that those users have been notified of its availability.

James Robert Matthews

Water/Sewer Superintendent