Aberdeen Fire Rescue Department



Serving the community since 1921

910-944-7888 800 HOLLY STREET ABERDEEN, NC 28315

Fax: 910-944-9755



Sprinkler Systems

Building:	
Address:	
	Date:
	Outstanding Violations: Yes No
GENERAL Date Sprinklers installed:	
Were building alterations/renovations made since la Was a new sprinkler added since last inspection? Ye	-
Any sprinkler system alteration made since last insp What is system type? Wet \square Dry \square Preaction \square Delu Is building fully protected with sprinklers? Yes \square If not, explain:	pection? Yes □ No □ uge □
Sprinkler Valves Do sprinkler valves appear in good working order? Is dry pipe valve in heated enclosure? Yes □ No □ Are spare sprinklers provided? Yes □ No □	
Control Valves Are control valves sealed? Yes □ No □ Are they locked? Yes □ No □ N/A □ Do they have tamper switches? Yes □ No □ N/A	
Fire Department Connections Are fire department connections clear and unobstructure and protective caps in place? Yes □ No □ N/A □ Are connections identified? Yes □ No □ N/A □	cted? Yes No N/A
Inspections and Tests Recorded Are quarterly inspections and tests recorded? Yes □ Are semiannual inspections and tests recorded? Yes Are annual inspections and tests recorded? Yes □	$s \square No \square N/A \square$

<u>Inspections and Tests Recorded</u>
Are 3 year dry Pipe full flow trip tests recorded? Yes \square No \square N/A \square
Are 5 year alarm valve internal inspection recorded? Yes □ No □ N/A □
20 Years – Is sample of fast response sprinklers tested? Yes \square No \square N/A \square
50 Years – Is sample of standard response sprinklers tested? Yes □ No □ N/A □
Notes:

Date:

Fire Inspector